

Customer/Site Details		Company Details	
Customer Name	Kam Bamrah	Contact Phone	01622 729825
Address	20-22 Lottbridge Drove Eastbourne, East Sussex BN23 6NS The Hendy Group	Address	Unit 7 & 8, 1B Whitmore Street Maidstone ME16 8JX
Contact Phone	01892731456	Tech OFTEC No.	5638436
		Co. OFTEC No.	

PRE-COMMISSIONING CHECKS

Confirm the required appliance heat output rating from the heating designer/installer and insert here 60 kW

Appl. Make & Model	Powrmatic OUH60/F/1	Serial No.	O6017L384954
Burner Make & Model	Riello 40 G10	Burner Type	PJ
Tank Type	Bunded	Flue Type	CF
Fuel Type	D	Call Type	Service

OIL FIRING SERVICE & COMMISSIONING SCHEDULE

Schedule Item	Checked?	Passed?	Parts Fitted/Observations
Oil storage	Yes	Yes	
Oil supply system	Yes	Yes	
Air supply	Yes	Yes	
Chimney/flue	Yes	Yes	
Electrical safety	N/A		
Heat exchanger	Yes	Yes	
Combustion chamber	Yes	Yes	
Pressure jet burner	Yes	Yes	
Vaporising & wallflame burner	N/A		
Wallflame burner (additional)	N/A		
Appliance safety controls	Yes	Yes	
Heating system service	N/A		
Controls check	Yes	Yes	
System check – Hot water type	N/A		
System check – Warm air type	N/A		

IMPORTANT COMMENTS


TEST RESULTS

As required by BS5410:1, combustion test results have been produced electronically & a printout has been provided with this form

Pump pressure	15 bar	Efficiency nett	82.9%	Efficiency gross	78 %
Pump vacuum	- bar	Draught	- mmWG	Flue gas temp	308.7 °C
Smoke No.	-	CO	0 ppm	Excess air	56.9 %
Nozzle size	1.25	Nozzle angle	45°	Nozzle pattern	S
Flow rate (oil) low	- cc/min	Flow rate (oil) high	- cc/min	CO ₂	9.88 %
Flow rate (DHW) cold	- l/min	Flow rate (DHW) hot	- cc/min		

RECEIPT OF REPORT

I acknowledge receipt of this service and commissioning report.

Recipient's Name	Dave Jenkins	Recipient's Status	Workshop Manager
Recipient's Signature		Date	11/04/2024

TECHNICIAN'S DETAILS

Name	George Bowles Bowles	Signature		Date	11/04/2024
------	----------------------	-----------	--	------	------------